

# PWS Information

**Purpose of this worksheet:** For water systems to document basic system information. All information on this page is required.

## Facility Information\*

Water System Name:

City of Jefferson

PWSID:	Population Served (number of people):	Number of Service Connections:	PWS Type:
TX1580001	1,883	1325	CWS

If a CWS, do multi-family residences comprise at least 20% of the structures you serve? No

## System Contact Person\*

Name:	Title:
Allan Whatley	Director of Public Works
Telephone:	Email:
903-665-3922	whatley@cityofjefferson.com

## Person Who Prepared Inventory (if different from above)\*

Name:	Title/Affiliation:
Lisa Crossman, P.E.	Project Manager, Schaumburg & Polk. Inc.
Telephone:	Email:
903-595-3913	lcrossman@spi-eng.com

# Inventory Methodology

PWS Name: City of Jefferson  
PWSID: TX1580001

**Purpose of this worksheet:** For systems to document the methods and resources they used to develop and update the inventory.  
**Note:** Cells that have a superscript <sup>x</sup> are required fields.

## Part 1: Historical Records Review

Type of Record	Describe the Records Reviewed for Your Inventory <sup>x</sup>	Indicate if record was reviewed as required by 40 § CFR 141.84(a)(3). <sup>x</sup>
1. Previous Materials Evaluation <i>Example: Locations of Tier 1 lead tap sampling locations that are served by a lead service line.</i>		No
2. Construction Records and Plumbing Codes <i>Examples: Local ordinance adopting an international plumbing code. Permits for replacing lead service lines.</i>		No
3. Water System Records <i>Examples: Capital improvement plans. Standard operating procedures. Engineering standards.</i>		No
4. Distribution System Inspections and Records <i>Examples: Distribution system maps. Tap cards. Service line repair/replacement records. Inspection records. Meter installation records.</i>		No
5. Other Records	Visual inspections of every water meter	Yes

## Part 2: Identifying Service Line Material During Normal Operations

1. During which normal operating activities are you collecting information on service line material? Check all that apply. **Note that under 40 § CFR 141.84(a)(5) water systems must identify and track service line materials in the inventory as they are encountered in the course of its normal operations.**

Water meter reading	No	Water main repair or replacement	No
Water meter repair or replacement	No	Water main repair or replacement	No
Service line repair or replacement	No	Backflow prevention device inspection	No
Other	Yes		

If "Other", please explain below:

**Visual inspection by consultant of every water meter**

2. Did you develop or revise standard operating procedures to collect service line material information during normal operation? If "Yes", please explain below.

No

## Part 3: Service Line Investigations

1. Identify the service line investigation methods your system used to prepare the inventory (check all that apply). If a water system chooses an investigation method not specified by the state under 40 CFR §141.84(a)(3)(iv), state approval is required. **Note that investigations are not required by the LCRR but can be used by systems to assess accuracy of historical records and gather information when service line material is unknown.**

Visual inspection at the Meter Pit	Yes	Water Quality Sampling - Sequential	No
Customer Self-Identification	No	Water Quality Sampling - Other	No
CCTV Inspection at Curb Box - External	No	Mechanical Excavation	No
CCTV Inspection at Curb Box - Internal	No	Vacuum Excavation	No
Water Quality Sampling - Targeted	No	Predictive Modeling	No
Water Quality Sampling - Flushed	No	Other	No

If "Other", please explain below:

2. If "Predictive Modeling", please briefly describe the model and inputs used:

# Inventory Summary

PWS Name: City of Jefferson  
 PWSID: TX1580001

**Purpose of this worksheet:** For water systems to provide a summary of the service line inventory, including information on ownership, inventory format, and the number of service lines for each of the four required materials classifications.

**Note:** Cells that have a superscript <sup>x</sup> are required fields.

## Part 1. General Information

1. Is this the <b>Initial Inventory</b> or an <b>Inventory Update</b> ? <sup>x</sup>	Initial Inventory
2a. Who <b>owns the service lines</b> in your system? <i>If other, please explain below.</i> <sup>x</sup>	Ownership is split
2b. Is there documentation that defines service line ownership in your system, such as a local ordinance? <i>If yes, please describe below and explain where ownership is split (e.g., property line, curb stop).</i>	No
3a. Describe when lead service lines were generally installed in your system below.  <b>If lead service lines were installed, they would have been installed prior to the passage of 30 TAC 290.44(b), which bans the use of lead in plumbing</b>	
3b. When were lead service lines banned for the system? Reference the state or local ordinance that banned the use of lead in your system.  <b>With passage of 30 TAC 290.44(b), which bans the use of lead in plumbing</b>	
4. Are there lead goosenecks, pigtails or connectors in the system?	Don't Know

## Part 2. Inventory Summary Table <sup>1</sup>

When using the **Detailed Inventory** worksheet, the classifications in the Column "Entire Service Line Material Classification" (Column Q) will be used to calculate the total number of service lines for each of the four material classifications below. **Remember this is the classification for the entire service line.**

Service Line Material Classification	Definition	Total Number of Service Lines (REQUIRED to be reported under the LCRR) <sup>x</sup>
<b>Lead</b>	Any portion of the service line is known to be made of lead. <sup>2</sup>	3
<b>Galvanized Requiring Replacement (GRR)</b>	The service line is not made of lead, but a portion is galvanized and the system is unable to demonstrate that the galvanized line was never downstream of a lead service line.	131
<b>Non-Lead</b>	All portions of the service line are known NOT to be lead or GRR through an evidence-based record, method, or technique.	1,049
<b>Lead Status Unknown</b>	The service line material is not known to be lead or GRR. For the entire service line or a portion of it (in cases of split ownership), there is not enough evidence to support material classification.	203
<b>TOTAL</b>		1,386

### Notes

<sup>1</sup> This summary table is for reporting material for the entire service line connecting the water main to the customer's plumbing. See the **Classifying SLs** worksheet for additional guidance on assigning a materials classification to the entire service line when ownership is split. Remember that systems must track the system-owned and customer-owned portions separately in their inventory.

<sup>2</sup> A lead-lined galvanized service line is consistent with the definition of an LSL under the LCRR ("a portion of pipe that is made of lead, which connects the water main to the building inlet") (40 CFR §141.2) and must therefore be classified in the inventory as an LSL. Do not, however, count non-lead service lines with a lead gooseneck or pigtail as lead service lines.

Location Information					System-Owned Portion							Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement			
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>5</sup>	Notes	Entire Service Line Material Classification <sup>7</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR	
	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>																						
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.							Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead	Note: This information may be helpful for identifying lead tap monitoring locations.							
923	204	Black Cypress St	Jefferson	75657		32.7639651	-94.3616251	Non-Lead - Plastic	Don't Know	Unknown	Poly	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5		
305	1	Bulldog Dr	Jefferson	75657	Jefferson high school	32.7766315	-94.3623889	Galvanized		Unknown	Cast iron	Non-Lead - Plastic	Unknown	Cast iron flange couples to plastic - PVC	Don't Know	Don't Know								Tier 5		
1050	707	Common st	Jefferson	75657		32.7499306	-94.3480238	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5		
314	503	E Baker St	Jefferson	75657		32.7584341	-94.3496629	Galvanized		Unknown	Cast iron, magnetic.	Non-Lead - Plastic	Unknown	PVC	Don't Know	Don't Know								Tier 5		
691	701	E Bonham St	Jefferson	75657	Cabinet shop out building	32.7646931	-94.3427310	Galvanized		Unknown		Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5		
92	404	E Broadway St	Jefferson	75657		32.7607488	-94.3513897	Galvanized		Unknown	Cast iron. Box bad.	Non-Lead - Plastic	Unknown	PVC	Don't Know	Don't Know								Tier 5		
703	101	E Broadway st	Jefferson	75657		32.7613873	-94.3541498	Galvanized		Unknown	Cast iron	Galvanized	Unknown	Cast iron	Don't Know	Don't Know								Tier 5		
709	109	E Broadway st	Jefferson	75657		32.7615737	-94.3539974	Galvanized		Unknown	Cast iron	Non-Lead - Copper	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5		
241	401	E Clarksville st	Jefferson	75657		32.7619254	-94.3449756	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know							Tier 5		
486	108	E Clarksville st	Jefferson	75657		32.7590375	-94.3481510	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Galvanized	Unknown	Under asphalt drive	Galvanized Requiring Replacement	Don't Know	Don't Know							Tier 5		
954	101	E Clay	Jefferson	75657	House	32.7635945	-94.3546855	Galvanized		Unknown		Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
957	107	E Clay	Jefferson	75657	House	32.7635531	-94.3543239	Galvanized		Unknown		Non-Lead - Copper	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5		
963	201	E Clay	Jefferson	75657	House	32.7635611	-94.3536531	Galvanized		Unknown	Poly likely connected to galvanized pipe	Non-Lead - Copper	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5		
965	205	E Clay	Jefferson	75657	House	32.7635588	-94.3531101	Galvanized		Unknown	Poly connector to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
971	304	E Clay	Jefferson	75657	House	32.7633368	-94.3524930	Galvanized		Unknown	Poly connector to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
973	306	E Clay	Jefferson	75657	Garage - may be N Alley address	32.7633927	-94.3519839	Galvanized		Unknown	Tree roots are bad on lines and box	Galvanized	Unknown	Galvanized	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
955	102	E Clay	Jefferson	75657	Abandoned warehouse	32.7634166	-94.3546433	Galvanized		Unknown	PVC	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
956	103	E Clay	Jefferson	75657	House	32.7635590	-94.3545739	Galvanized		Unknown	Possible dual connection with 101	Non-Lead	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5		
989	301	E Clay	Jefferson	75657	House	32.7636601	-94.3525234	Non-Lead - Plastic	Don't Know	Unknown	Poly - likely connected to galvanized	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
966	210	E Clay	Jefferson	75657	House	32.7632290	-94.3526707	Non-Lead - Plastic	Don't Know	Unknown	Poly likely connected to galvanized	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
409	703	E delta st	Jefferson	75657		32.7576524	-94.3489204	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know							Tier 5		
46	306	E delta st	Jefferson	75657		32.7573381	-94.3523360	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know							Tier 5		
298	608	E Delta St	Jefferson	75657		32.7573949	-94.3495379	Non-Lead - Plastic	Don't Know	Unknown	poly. bad box	Galvanized	Unknown	cast iron.	Galvanized Requiring Replacement	Don't Know	Don't Know							Tier 5		
300	502	E Delta St	Jefferson	75657		32.7573706	-94.3499812	Non-Lead - Plastic	Don't Know	Unknown	poly. good box	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5		
42	206	E delta st	Jefferson	75657		32.7572975	-94.3527258	Galvanized		Unknown	Non magnetic metal. Meter box good	Galvanized	Unknown	Non magnetic metal	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
122	401	E delta st	Jefferson	75657		32.7574449	-94.3513213	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Galvanized	Unknown	Non magnetic metal	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
96	409	E Dixon St	Jefferson	75657		32.7606067	-94.3503542	Non-Lead - Plastic	Don't Know	Unknown	poly. decent box	Galvanized	Unknown	cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
323	605	E Dixon St	Jefferson	75657		32.7606823	-94.3490334	Non-Lead - Plastic	Don't Know	Unknown	poly	Galvanized	Unknown	cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
89	402	E Dixon St	Jefferson	75657		32.7602132	-94.3514039	Galvanized		Unknown	Probably cast iron. meter box decent condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
17	201	E Dixon St	Jefferson	75657		32.7604352	-94.3535296	Non-Lead - Copper	Don't Know	Unknown	Meter box in good condition.	Galvanized	Unknown	iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
897	303	E Douglas	Jefferson	75657	House	32.7678057	-94.3525074	Non-Lead - Copper	Don't Know	Unknown		Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
844	407	E Douglas St	Jefferson	75657	House	32.7676327	-94.3507590	Non-Lead - Copper	Don't Know	Unknown		Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
950	109	E Elizabeth	Jefferson	75657	House	32.7625515	-94.3540652	Non-Lead - Copper	Don't Know	Unknown		Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
1132	301	E Harrison	Jefferson	75657	House	32.7685366	-94.3522262	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
1143	202	E Harrison	Jefferson	75657	House	32.7684107	-94.3535884	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
50	210	E Jefferson st	Jefferson	75657		32.7561686	-94.3527500	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Galvanized	Unknown	Too deep	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
134	408	E Jefferson st	Jefferson	75657		32.7563186	-94.3507353	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
285	605	E Jefferson St	Jefferson	75657		32.7564223	-94.3492317	Non-Lead - Plastic	Don't Know	Unknown	poly. good box	Galvanized	Unknown	cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
159	110	E Lafayette st	Jefferson	75657		32.7578251	-94.3444904	Galvanized		Unknown	Non magnetic metal. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
160	110	E Lafayette st	Jefferson	75657		32.7578137	-94.3444643	Galvanized		Unknown	Good box	Non-Lead - Copper	Unknown	Non-Lead	Don't Know	Don't Know									Tier 5	
161	110	E Lafayette st	Jefferson	75657		32.7577891	-94.3444358	Galvanized		Unknown	Cast iron. Good box	Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
139	306	E Lafayette St	Jefferson	75657		32.7592117	-94.3427340	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box.	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
717	208	E Moseley st	Jefferson	75657		32.7541924	-94.3529460	Non-Lead - Copper	Don't Know	Unknown		Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
55	405	E Taylor st	Jefferson	75657		32.7553091	-94.3512885	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Galvanized	Unknown	Too deep	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
57	307	E Taylor st	Jefferson	75657		32.7552989	-94.3519722	Non-Lead - Plastic	Don't Know	Unknown	Poly. Bad box	Galvanized	Unknown	Non magnetic metal.	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
53	303	E Taylor st	Jefferson	75657		32.7552985	-94.3523039	Galvanized		Unknown	Magnetic metal cast. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
54	306	E Taylor st	Jefferson	75657		32.7552261	-94.3521529	Galvanized		Unknown	Magnetic metal. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
359	605	E walker st	Jefferson	75657		32.7594362	-94.3492325	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Galvanized	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
111	410	E Walker St	Jefferson	75657		32.7589262	-94.3503519	Non-Lead - Copper	Don't Know	Unknown	bad box	Galvanized	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5	
109	407	E Walker St	Jefferson	75657		32.7594639	-94.3505207	Non-Lead - Plastic	Don't Know	Unknown	poly. good box	Galvanized	Unknown	cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
26	201	E walker St	Jefferson	75657		32.7594326	-94.3535131	Galvanized		Unknown	Cast iron. Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
33	301	E walker st	Jefferson																							



Location Information					System-Owned Portion				Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers				Lead Service Line Replacement							
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>5</sup>	Is there a Lead Connector? <sup>7</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR	
	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>																						
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.						Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead			Note: This information may be helpful for identifying lead tap monitoring locations.						
991	211	N Friou	Jefferson	75657	Vacant lot - Corner of E Clay	32.7636773	-94.3526734	Non-Lead - Plastic	Don't Know	Unknown	Poly - likely connected to galvanized	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
593	102	N Friou st	Jefferson	75657		32.7618624	-94.3525111	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
896	703	N Friou St	Jefferson	75657	House	32.7678880	-94.3526502	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										Tier 5
809	310	N Main Street	Jefferson	75657	House	32.7633665	-94.3496451	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
251	1860	N Market st	Jefferson	75657		32.7572877	-94.3474846	Galvanized	Unknown	Unknown	Cast. Good box	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
261	212	N Market st	Jefferson	75657		32.7570699	-94.3474498	Galvanized	Unknown	Unknown	Cast. Bad box	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
275	114	N Marshall St	Jefferson	75657		32.7551722	-94.3474306	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Unknown	Bad	Galvanized Requiring Replacement	Don't Know	Don't Know										
959	207	N Owens	Jefferson	75657	House	32.7630856	-94.3538674	Galvanized	Unknown	Unknown	Galvanized	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
960	205	N Owens	Jefferson	75657	House	32.7629148	-94.3538586	Galvanized	Unknown	Unknown	Galvanized	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
961	226	N Owens	Jefferson	75657	Duplex	32.7634223	-94.3534666	Galvanized	Unknown	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know										Tier 5
962	228	N Owens	Jefferson	75657	Duplex	32.7634364	-94.3534831	Galvanized	Unknown	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know										Tier 5
997	305	N Owens	Jefferson	75657	House	32.7637632	-94.3538553	Non-Lead - Plastic	Don't Know	Unknown	Poly - likely connected to galvanized	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
1145	703	N Owens	Jefferson	75657	House	32.7678659	-94.3538442	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
779	216	n polk	Jefferson	75657		32.7580517	-94.3454450	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	best guess. under concrete	Galvanized Requiring Replacement	Don't Know	Don't Know										
201	209	N Polk st	Jefferson	75657		32.757928	-94.3454272	Galvanized	Unknown	Unknown	No meter, good box. Cast iron	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
158	118	N Polk St	Jefferson	75657		32.7574764	-94.3443146	Non-Lead - Copper	Don't Know	Unknown	decent box	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
569	202	N Polk st	Jefferson	75657		32.7582536	-94.3445299	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Under concrete sidewalk	Galvanized Requiring Replacement	Don't Know	Don't Know										
493	419	N Polk st	Jefferson	75657		32.7595608	-94.3472652	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
494	419	N Polk st	Jefferson	75657		32.7595051	-94.3471764	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
495	409	N Polk st	Jefferson	75657		32.7592953	-94.3469880	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
504	402	N Polk St	Jefferson	75657		32.7593252	-94.3463770	Galvanized	Unknown	Unknown	Cast iron	Unknown	Unknown	Non-Lead	Don't Know	Don't Know										Tier 5
534	314	N Polk st	Jefferson	75657		32.7587802	-94.3461915	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
536	316	N Polk st	Jefferson	75657		32.7587868	-94.3462008	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
542	317	N Polk st	Jefferson	75657		32.7586854	-94.3463500	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
167	116	N Polk st	Jefferson	75657		32.7573115	-94.3447335	Galvanized	Unknown	Unknown	Good box	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
286	602	N Soda st	Jefferson	75657		32.7620179	-94.3466271	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
235	307	N Soda st	Jefferson	75657		32.7598865	-94.3445975	Non-Lead - Copper	Don't Know	Unknown	Good box	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
179	122	N Vale st	Jefferson	75657		32.7567534	-94.3458031	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Unknown	Cast	Galvanized Requiring Replacement	Don't Know	Don't Know										
485	410	N Vale st	Jefferson	75657		32.7590255	-94.3481319	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Under concrete sidewalk	Galvanized Requiring Replacement	Don't Know	Don't Know										
180	120	N Vale st	Jefferson	75657		32.7567657	-94.3457451	Galvanized	Unknown	Unknown	Good box	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
1172	707	N Walcott	Jefferson	75657	Tire shop	32.7683953	-94.3533109	Galvanized	Unknown	Unknown	Unknown	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
1011	307	N Walcott	Jefferson	75657	House	32.7641006	-94.3551340	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
157	115	N Walnut St	Jefferson	75657		32.7575826	-94.3440957	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
502	403	N Walnut St	Jefferson	75657		32.7594743	-94.3462786	Galvanized	Unknown	Unknown	Cast iron	Unknown	Cast iron	Non-Lead	Don't Know	Don't Know										Tier 5
503	403	N Walnut St	Jefferson	75657		32.7594716	-94.3462697	Galvanized	Unknown	Unknown	Cast iron	Unknown	Lead	Lead connector to copper pipe	Don't Know	Don't Know										
511	409	N Walnut St	Jefferson	75657		32.7602449	-94.3468390	Galvanized	Unknown	Unknown	Cast iron	Unknown	Non-Lead - Plastic	Non-Lead	Don't Know	Don't Know										Tier 5
421	605	N Walnut st	Jefferson	75657		32.7615397	-94.3478435	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know										
508	520	N Walnut st	Jefferson	75657		32.7610174	-94.3472371	Non-Lead - Plastic	Don't Know	Unknown	poly	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know										
525	404	N Walnut St	Jefferson	75657		32.7599431	-94.3456001	Non-Lead - Plastic	Don't Know	Unknown	black poly	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know										
549	224	N Walnut st	Jefferson	75657		32.7588722	-94.3449651	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know										
636	1205	North St	Jefferson	75657	Garage-dwelling	32.7731171	-94.3411602	Non-Lead - Plastic	Don't Know	Unknown	Unable to locate	Unknown	Unable	Galvanized Requiring Replacement	Don't Know	Don't Know										
332	1311	Pine Hills Dr	Jefferson	75657	House	32.7751071	-94.3580539	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
644	110	Pvt Road 7208	Jefferson	75657		32.7417066	-94.3386787	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Cast iron	Galvanized Requiring Replacement	Don't Know	Don't Know										
81	305	S Alley St	Jefferson	75657		32.7589878	-94.3515355	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
127	503	S alley st	Jefferson	75657		32.7573278	-94.3519195	Non-Lead - Plastic	Don't Know	Unknown	Poly. Bad box	Unknown	Lead-lined galvanized	Lead	Don't Know	Don't Know										
87	201	S Alley St	Jefferson	75657		32.7601288	-94.3515293	Non-Lead - Copper	Don't Know	Unknown	meter box bad	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know										
70	404	S Alley St	Jefferson	75657		32.7585796	-94.3514180	Galvanized	Unknown	Unknown	Cast Iron. Meter box in good condition.	Unknown	Cast Iron. Meter Box In Good Condition	Galvanized Requiring Replacement	Don't Know	Don't Know										
735	1010	S alley st	Jefferson	75657		32.7524937	-94.3514430	Galvanized	Unknown	Unknown	Cast iron	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
317	307	S Bridge	Jefferson	75657		32.7588501	-94.3496467	Non-Lead - Copper	Don't Know	Unknown	non-magnetic	Unknown	cast iron, strongly magnetic	Galvanized Requiring Replacement	Don't Know	Don't Know										
102	201	S Bridge St	Jefferson	75657		32.7602009	-94.3502180	Non-Lead - Copper	Don't Know	Unknown	Cast iron, strongly magnetic	Unknown	PVC	Galvanized Requiring Replacement	Don't Know	Don't Know										
315	310	S Bridge St	Jefferson	75657		32.7586246	-94.3495457	Galvanized	Unknown	Unknown	Cast iron, strongly magnetic	Unknown	PVC	Non-Lead	Don't Know	Don't Know										Tier 5
316	308	S Bridge St	Jefferson	75657		32.7586843	-94.3495367	Galvanized	Unknown	Unknown	Cast iron, strongly magnetic	Unknown	PVC	Non-Lead	Don't Know	Don't Know										





Location Information					System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers				Lead Service Line Replacement						
Unique Service Line ID	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>	Location Identifier <sup>2</sup>	Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>1</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>1</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>1</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
299	607	E Delta St	Jefferson	75657			32.7574519	-94.3493527	Non-Lead - Plastic	Don't Know	Unknown	poly, bad box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
301	504	E Delta St	Jefferson	75657			32.7573480	-94.3497254	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
302	504	E Delta St	Jefferson	75657			32.7573416	-94.3497378	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
117	410	E Delta St	Jefferson	75657			32.7573414	-94.3506767	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Copper	Unknown	Good	Non-Lead	Don't Know	Don't Know							Tier 5	
118	409	E Delta St	Jefferson	75657			32.7574690	-94.3504981	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Copper	Unknown	Good	Non-Lead	Don't Know	Don't Know							Tier 5	
123	401	E delta st	Jefferson	75657			32.7574386	-94.3513594	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
324	605	E Dixon St	Jefferson	75657			32.7605006	-94.3490090	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
13	202	E Dixon St	Jefferson	75657			32.7603356	-94.3535202	Non-Lead - Plastic	Don't Know	Unknown	Meter box decent condition	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
14	202	E Dixon St	Jefferson	75657			32.7603366	-94.3535146	Non-Lead - Copper	Don't Know	Unknown	Meter box decent condition	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
93	407	E Dixon St	Jefferson	75657			32.7604565	-94.3507646	Non-Lead - Copper	Don't Know	Unknown	bad box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
95	400	E Dixon St	Jefferson	75657			32.7603469	-94.3511622	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
98	505	E Dixon St	Jefferson	75657			32.7606787	-94.3501627	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
16	203	E Dixon St	Jefferson	75657			32.7604350	-94.3531956	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box bad condition.	Non-Lead - Plastic	Unknown	Poly. Meter Box Bad Condition	Non-Lead	Don't Know	Don't Know							Tier 5	
18	201	E Dixon St	Jefferson	75657			32.7604423	-94.3535451	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box in bad condition.	Non-Lead - Plastic	Unknown	Poly. Meter Box in Bad Condition	Non-Lead	Don't Know	Don't Know							Tier 5	
90	402	E Dixon St	Jefferson	75657			32.7602005	-94.3513936	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	Meter Box Decent Condition - PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
99	404	E Dixon St	Jefferson	75657			32.7603896	-94.3506982	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	Box - PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
91	401	E Dixon St	Jefferson	75657			32.7604569	-94.3512139	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box bad	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
864	312	E Douglas	Jefferson	75657	House		32.7673958	-94.3515775	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
883	106	E Douglas	Jefferson	75657	House		32.7674545	-94.3542264	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
899	306	E Douglas	Jefferson	75657	House		32.7674645	-94.3520668	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
900	305	E Douglas	Jefferson	75657	House		32.7673238	-94.3520408	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
825	513	E Douglas	Jefferson	75657	Duplex		32.7678477	-94.3487203	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
836	511	E Douglas	Jefferson	75657	Duplex		32.7678439	-94.3487989	Non-Lead - Copper	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
887	103	E Douglas	Jefferson	75657	Auto Repair		32.7675573	-94.3545415	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
890	201	E Douglas	Jefferson	75657	House		32.7677765	-94.3536501	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
892	203	E Douglas	Jefferson	75657	House		32.7675630	-94.3532825	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
884	102	E Douglas	Jefferson	75657	Serenity Martuary		32.7674416	-94.3547311	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
859	402	E Douglas	Jefferson	75657	Vacant lot		32.7674218	-94.3520207	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
888	103	E Douglas	Jefferson	75657	Back lot of auto repair		32.7675633	-94.3545037	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
891	200	E Douglas	Jefferson	75657	House		32.7673108	-94.3536308	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
893	206	E Douglas	Jefferson	75657	House		32.7674667	-94.3531392	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
837	509	E Douglas St	Jefferson	75657	Duplex		32.7678559	-94.3492308	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
838	507	E Douglas St	Jefferson	75657	Duplex		32.7678635	-94.3492420	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
839	503	E Douglas St	Jefferson	75657	Duplex		32.7678445	-94.3496598	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
840	505	E Douglas St	Jefferson	75657	Duplex		32.7678580	-94.3497290	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
938	311	E Elizabeth	Jefferson	75657	House		32.7626029	-94.3517143	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
941	302	E Elizabeth	Jefferson	75657	Vacant lot		32.7624306	-94.3524079	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
936	408	E Elizabeth	Jefferson	75657	House		32.7623986	-94.3506968	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
937	403	E Elizabeth	Jefferson	75657	House		32.7625550	-94.3507138	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
940	304	E Elizabeth	Jefferson	75657	House		32.7624360	-94.3522094	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
967	205	E Elizabeth	Jefferson	75657	House		32.7626152	-94.3526701	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
968	205	E Elizabeth	Jefferson	75657	Sprinkler		32.7625847	-94.3527419	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
794	602	E Elizabeth St	Jefferson	75657	House		32.7620608	-94.3494881	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
795	506	E Elizabeth St	Jefferson	75657	House		32.7622565	-94.3496998	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
796	604	E Elizabeth St	Jefferson	75657	House		32.7624541	-94.3490829	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
797	604	E Elizabeth St	Jefferson	75657	Vacant lot		32.7624465	-94.3490260	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
804	501	E Elizabeth St	Jefferson	75657	House		32.7626588	-94.3501923	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
23	108	E Friou St	Jefferson	75657			32.7608183	-94.3525837	Non-Lead - Copper	Don't Know	Unknown	Meter box in good condition	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
1147	102	E Harrison	Jefferson	75657	Lot absorbed by auto repair shop		32.7684257	-94.3546230	Non-Lead	Don't Know	Unknown	No meter set	Non-Lead	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
866	402	E Harrison	Jefferson	75657	Duplex		32.7683599	-94.3510304	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
867	404	E Harrison	Jefferson	75657	House		32.7683563	-94.35102																		

Location Information					System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement				
Unique Service Line ID	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>	Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>2</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>2</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>2</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
<p>A Unique ID is recommended for each service line.</p> <p>Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.</p> <p>Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown</p> <p>Select Yes, No, or Don't Know. Important for determining if downstream/customer-owned galvanized service line requires replacement</p> <p>Dropdown list when the service line was installed or replaced</p> <p>Use this field for documenting additional relevant information, including when classification changes</p> <p>Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.</p> <p>Date, year, or estimated date range when the service line was installed or replaced</p> <p>Can use this field for documenting additional relevant information, including when classification changes</p> <p>For example, lead gossneck or pithead where the water main is connected to the service line</p> <p>Select Yes, No, or Don't Know</p> <p>For example, backflow preventer or meter containing lead</p> <p>Note: This information may be helpful for identifying lead tap monitoring locations.</p>																									
58	310	E Taylor st	Jefferson	75657		32.7552106	-94.3516672	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
364	701	E Walker st	Jefferson	75657		32.7594262	-94.3489073	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
372	702	E Walker st	Jefferson	75657		32.7591688	-94.3489093	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
375	310	E Walker st	Jefferson	75657		32.7589775	-94.3489098	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
105	408	E Walker St	Jefferson	75657		32.7594071	-94.3510022	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
107	410	E Walker St	Jefferson	75657		32.7593461	-94.3505670	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
108	410	E Walker St	Jefferson	75657		32.7593336	-94.3505663	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
112	502	E Walker St	Jefferson	75657		32.7588041	-94.3502246	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	pex	Non-Lead	Don't Know	Don't Know								Tier 5	
319	602	E Walker St	Jefferson	75657		32.7593226	-94.3493943	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
318	602	E Walker St	Jefferson	75657		32.7593344	-94.3493834	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
103	502	E Walker St	Jefferson	75657		32.7593793	-94.3507193	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know								Tier 5	
106	408	E Walker St	Jefferson	75657		32.7593467	-94.3507199	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know								Tier 5	
110	407	E Walker St	Jefferson	75657		32.7594753	-94.3507060	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know								Tier 5	
104	501	E Walker St	Jefferson	75657		32.7594276	-94.3501224	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Decent Box - PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
320	601	E Walker St	Jefferson	75657		32.7594663	-94.3495193	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
871	305	E Webster	Jefferson	75657	House	32.7665988	-94.3520308	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
872	303	E Webster	Jefferson	75657	House	32.7665744	-94.3521115	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
875	211	E Webster	Jefferson	75657	House - no radio read meter	32.7665555	-94.3529680	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
852	405	E Webster	Jefferson	75657	Vacant lot	32.7665526	-94.3506572	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know								Tier 5	
540	515	E Whelan	Jefferson	75657	House	32.7702448	-94.3485948	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
541	513	E Whelan	Jefferson	75657	House	32.7702497	-94.3488312	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
543	511	E Whelan	Jefferson	75657	House	32.7702507	-94.3490874	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
544	509	E Whelan	Jefferson	75657	House	32.7702386	-94.3494811	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
545	507	E Whelan	Jefferson	75657	House	32.7702540	-94.3498302	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
547	505	E Whelan	Jefferson	75657	House	32.7702682	-94.3501285	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
548	503	E Whelan	Jefferson	75657	House	32.7704413	-94.3508200	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
564	303	E Whelan	Jefferson	75657	House	32.7703066	-94.3532059	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
307	307	E Whelan	Jefferson	75657	House	32.7703401	-94.3526525	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
565	311	E Whelan	Jefferson	75657	House	32.7703241	-94.3525908	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Galvanized Requiring Replacement	Non-Lead	Don't Know	Don't Know							Tier 5	
575	401	E Whelan	Jefferson	75657	House	32.7703098	-94.3518900	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
576	401	E Whelan	Jefferson	75657	House Sprinkler	32.7703403	-94.3518393	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
577	405	E Whelan	Jefferson	75657	House	32.7703148	-94.3516785	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
578	407	E Whelan	Jefferson	75657	House	32.7703375	-94.3514258	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Galvanized	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
579	409	E Whelan	Jefferson	75657	House	32.7704722	-94.3509765	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know							Tier 5	
660	1101	E Whelan	Jefferson	75657	House	32.7701271	-94.3474164	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
661	603	E Whelan	Jefferson	75657	House	32.7702593	-94.3482625	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
749	608	Elm St	Jefferson	75657	House	32.7662590	-94.3453580	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1102	1102	FM 2208	Jefferson	75657		32.7661445	-94.3527481	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
1360	1759	FM 2208	Jefferson	75657		32.7661278	-94.3527501	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1365	931	FM 2208	Jefferson	75657		32.7665048	-94.3499404	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1366	930	FM 2208	Jefferson	75657		32.7668604	-94.3497600	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1367	900	FM 2208	Jefferson	75657		32.7669782	-94.3493996	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1368	759	FM 2208	Jefferson	75657		32.7370853	-94.3463803	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1369	649	FM 2208	Jefferson	75657		32.7378721	-94.3435813	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
303	500	FM 881	Jefferson	75657	West Fraser	32.7765741	-94.3627818	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1334	498	FM 881	Jefferson	75657	Pore Technology	32.7685780	-94.3671820	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
1363	1020	FM 2208	Jefferson	75657		32.7364276	-94.3512950	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1245	204	Groy St	Jefferson	75657		32.7662287	-94.3529079	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1247	208	Groy St	Jefferson	75657		32.7631507	-94.3599021	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1250	212	Groy St	Jefferson	75657		32.7633923	-94.3598694	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1251	300	Groy St	Jefferson	75657		32.7635081	-94.3598910	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead										



Location Information					System-Owned Portion					Customer-Owned Portion					Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers					Lead Service Line Replacement				
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>7</sup>	Notes	Entire Service Line Material Classification <sup>8</sup>	Is there a Lead Connector? <sup>9</sup>	Is there Lead Solder in the Service Line? <sup>10</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present? <sup>11</sup>	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988? <sup>12</sup>	Current LCR Sampling Site? <sup>13</sup>	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSR	Date of Customer-owned LSR		
	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>																							
<p>A Unique ID is recommended for each service line.</p> <p>Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.</p> <p>Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field.</p> <p>Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement.</p> <p>Dropdown list when the service line was installed or replaced.</p> <p>Use this field for documenting additional relevant information, including when classification changes.</p> <p>Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.</p> <p>Date, year, or estimated date range when the service line was installed or replaced.</p> <p>Can use this field for documenting additional relevant information, including when classification changes.</p> <p>Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown.</p> <p>For example, lead gooseneck or pigtail where the water main is connected to the service line.</p> <p>Select Yes, No, or Don't Know.</p> <p>For example, backflow preventer or meter containing lead.</p> <p>Note: This information may be helpful for identifying lead tap monitoring locations.</p>																											
362	502	Magnolia	Jefferson	75657	House	32.7702622	-94.3501091	Non-Lead - Copper	Don't Know	Unknown	Sprinkler meter	Non-Lead - Plastic	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5		
363	502	Magnolia	Jefferson	75657	House	32.7702657	-94.3601216	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
365	410	Magnolia	Jefferson	75657	Sprinkler Meter	32.7702189	-94.3600241	Non-Lead - Plastic	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
366	410	Magnolia	Jefferson	75657	House	32.7702002	-94.3599859	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
370	406	Magnolia	Jefferson	75657	House	32.7702778	-94.3597860	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
371	406	Magnolia	Jefferson	75657	Vacant lot	32.7700999	-94.3593125	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
373	402	Magnolia	Jefferson	75657	House	32.7698237	-94.3586164	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
374	402	Magnolia	Jefferson	75657	House	32.7698300	-94.3586274	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
354	411	Magnolia Ct	Jefferson	75657	House	32.7707117	-94.3595597	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
307	1600	MLK Dr	Jefferson	75657	Jefferson ISD	32.7755670	-94.3596200	Non-Lead - Copper	Don't Know	Unknown	Galvanized	Unknown	Unknown	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
412	807	MLK DR	Jefferson	75657	House	32.7693770	-94.3586881	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
1262	504	MLK DR	Jefferson	75657	House	32.7656848	-94.3583996	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1266	406	MLK DR	Jefferson	75657	House	32.7649837	-94.3585077	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1267	406	MLK DR	Jefferson	75657	House	32.7650025	-94.3584941	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1279	206	MLK DR	Jefferson	75657	House	32.7631205	-94.3584936	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1327	402	MLK Dr	Jefferson	75657	Single wide house	32.7647113	-94.3585304	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
313	1303	MLK Dr	Jefferson	75657	Apartments	32.7717942	-94.3592538	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
349	804	MLK Dr	Jefferson	75657	House	32.7711034	-94.3584324	Non-Lead - Plastic	Don't Know	Unknown	Black Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1256	501	MLK DR	Jefferson	75657	House	32.7653809	-94.3599011	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
1271	308	MLK DR	Jefferson	75657	House	32.7641317	-94.3585968	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1275	203	MLK DR	Jefferson	75657	House	32.7626823	-94.3586423	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1276	203	MLK DR	Jefferson	75657	House	32.7628853	-94.3586370	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1282	202	MLK DR	Jefferson	75657	House	32.7625354	-94.3585137	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1263	410	MLK DR	Jefferson	75657	House	32.7654151	-94.3584956	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1278	210	MLK DR	Jefferson	75657	House	32.7633121	-94.3585023	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	poly	Non-Lead	Don't Know	Don't Know								Tier 5	
1283	201	MLK DR	Jefferson	75657	House	32.7623146	-94.3586401	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
312	1303	MLK Dr	Jefferson	75657	Apartments	32.7714283	-94.3593185	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1272	306	MLK DR	Jefferson	75657	House	32.7640338	-94.3585116	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1274	203	MLK DR	Jefferson	75657	House	32.7625784	-94.3586350	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1277	203	MLK DR	Jefferson	75657	House	32.7627814	-94.3586394	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1280	208	MLK DR	Jefferson	75657	House	32.7631668	-94.3585121	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1281	204	MLK DR	Jefferson	75657	House	32.7627873	-94.3584978	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
309	1400	MLK Dr.	Jefferson	75657	Resident	32.7740350	-94.3588460	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
311	1303	MLK Dr.	Jefferson	75657	Apartments	32.7723250	-94.3591510	Non-Lead - Plastic	Don't Know	Unknown	PVC	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
723	409	Moseley st	Jefferson	75657	House	32.7543241	-94.3505632	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
862	601	N Alley	Jefferson	75657	Possibly to side lot	32.7669624	-94.3515312	Non-Lead - Copper	Don't Know	Unknown	Unknown	Galvanized	Unknown	Unknown	Unknown	Galvanized Requiring Replacement	Don't Know	Don't Know								Tier 5	
863	607	N Alley	Jefferson	75657	House	32.7670119	-94.3515046	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
978	203	N Alley	Jefferson	75657	Lot behind house	32.7628492	-94.3514982	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
842	702	N Alley	Jefferson	75657	House	32.7679454	-94.3511183	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1129	709	N Alley	Jefferson	75657	House	32.7681185	-94.3516706	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1130	711	N Alley	Jefferson	75657	Vacant lot	32.7683920	-94.3521257	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
870	601	N Alley	Jefferson	75657	House	32.7665961	-94.3518272	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	Unknown	Unknown	Non-Lead	Don't Know	Don't Know								Tier 5	
934	106	N Alley	Jefferson	75657	Jefferson PD - sprinkler meter	32.7624167	-94.3509998	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
935	106	N Alley	Jefferson	75657	Jefferson PD	32.7624289	-94.3510267	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
939	109	N Alley	Jefferson	75657	House	32.7624450	-94.3518898	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1126	804	N Alley	Jefferson	75657	Jefferson Middle School	32.7701403	-94.3509667	Non-Lead - Plastic	Don't Know	Unknown	PVC	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1127	804	N Alley	Jefferson	75657	Jefferson middle school sprinkler	32.7701345	-94.3509580	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	
1128	804	N Alley	Jefferson	75657	Jefferson Middle School Gym	32.7700734	-94.3498648	Non-Lead - Plastic	Don't Know	Unknown	PVC	Non-Lead - Plastic	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5	

Location Information					System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers				Lead Service Line Replacement					
Unique Service Line ID	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>	Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>2</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>2</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>2</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>2</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
<p>A Unique ID is recommended for each service line.</p> <p>Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.</p> <p>Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown</p> <p>Select Yes, No, or Don't Know. Important for determining if downstroke/customer-owned galvanized service line requires replacement</p> <p>Dropdown list when the service line was installed or replaced</p> <p>Use this field for documenting additional relevant information, including when classification changes.</p> <p>Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.</p> <p>Date, year, or estimated date range when the service line was installed or replaced</p> <p>Can use this field for documenting additional relevant information, including when classification changes.</p> <p>For example, lead gossneck or pithead where the water main is connected to the service line</p> <p>Select Yes, No, or Don't Know</p> <p>For example, backflow preventer or meter containing lead</p> <p>Note: This information may be helpful for identifying lead tap monitoring locations.</p>																									
946	210	N Owens	Jefferson	75657	Garden lot - 4 of 5 meters	32.7625572	-94.3536203	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
947	208	N Owens	Jefferson	75657	Duplex 5 of 5 meters	32.7625791	-94.3536188	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
998	307	N Owens	Jefferson	75657	House	32.7640017	-94.3538562	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1144	708	N Owens	Jefferson	75657	Vacant lot - no meter set	32.7681237	-94.3536794	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1146	709	N Owens	Jefferson	75657	House	32.7682289	-94.3538427	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1150	803	N Owens	Jefferson	75657	Duplex	32.7685657	-94.3538338	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
1152	809	N Owens	Jefferson	75657	House	32.7688207	-94.3538371	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1154	811	N Owens	Jefferson	75657	House	32.7691357	-94.3538411	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
876	509	N Owens	Jefferson	75657	Duplex	32.7681582	-94.3538461	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
878	505	N Owens	Jefferson	75657	Duplex	32.7661531	-94.3538640	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
879	503	N Owens	Jefferson	75657	Duplex	32.7661455	-94.3538633	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
880	501	N Owens	Jefferson	75657	Apartment home	32.7659490	-94.3538845	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
882	601	N Owens	Jefferson	75657	House	32.7668187	-94.3537971	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
995	310	N Owens	Jefferson	75657	House	32.7642515	-94.3536560	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
996	308	N Owens	Jefferson	75657	House	32.7640994	-94.3536923	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
999	311	N Owens	Jefferson	75657	House	32.7644790	-94.3540560	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
889	701	N Owens	Jefferson	75657	House	32.7676433	-94.3538695	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
943	202	N Owens	Jefferson	75657	Duplex 2 of 5 meters	32.7625679	-94.3536305	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
944	204	N Owens	Jefferson	75657	Duplex 2 of 5 meters	32.7626023	-94.3536230	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
945	206	N Owens	Jefferson	75657	Duplex 3 of 5 meters	32.7625917	-94.3536197	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
1151	805	N Owens	Jefferson	75657	Duplex	32.7687438	-94.3538259	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
1153	810	N Owens	Jefferson	75657	Single wide house	32.7691820	-94.3536631	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
877	507	N Owens	Jefferson	75657	Duplex	32.7661632	-94.3538639	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
707	106	N Owens	Jefferson	75657		32.7621366	-94.3537513	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Other	Unknown	Cast iron	Non-Lead	Don't Know	Don't Know							Tier 5	
424	602	N Polk st	Jefferson	75657		32.7607916	-94.3483265	Non-Lead	Don't Know	Unknown	Cast iron	Non-Lead - Other	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
427	523	N Polk st	Jefferson	75657		32.7605006	-94.3481691	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
475	317	N Polk st	Jefferson	75657		32.7584105	-94.3467315	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
479	401	N Polk st	Jefferson	75657		32.7583889	-94.3485408	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
492	421	N Polk st	Jefferson	75657		32.7597700	-94.3474709	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
496	401	N Polk St	Jefferson	75657		32.7592269	-94.3469376	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
497	410	N Polk St	Jefferson	75657		32.7594531	-94.3469079	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
498	410	N Polk St	Jefferson	75657		32.7594102	-94.3468540	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
509	524	N Polk St	Jefferson	75657		32.7603219	-94.3479106	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
539	318	N Polk st	Jefferson	75657		32.7589706	-94.3463868	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
483	401	N Polk st	Jefferson	75657		32.7588529	-94.3470716	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
484	401	N Polk st	Jefferson	75657		32.7589568	-94.3469247	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
513	502	N Polk St	Jefferson	75657		32.7600807	-94.3472612	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
520	220	N Polk st	Jefferson	75657		32.7585380	-94.3455340	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
546	302	N Polk st	Jefferson	75657		32.7586252	-94.3455886	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	Blue poly	Non-Lead	Don't Know	Don't Know							Tier 5	
563	214	N Polk st	Jefferson	75657		32.7582098	-94.3450479	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
202	203	N Polk st	Jefferson	75657		32.7577329	-94.3453284	Non-Lead - Plastic	Don't Know	Unknown	Bad box	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
188	207	N Polk st	Jefferson	75657		32.7574152	-94.3453026	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
207	51	N Polk st	Jefferson	75657		32.7566967	-94.3444585	Non-Lead - Plastic	Don't Know	Unknown	Good box - Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
476	317	N Polk st	Jefferson	75657		32.7584045	-94.3466986	Non-Lead - Plastic	Don't Know	Unknown	PVC	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
198	211	N Polk st	Jefferson	75657		32.7576465	-94.3456746	Non-Lead - Copper	Don't Know	Unknown	Good box	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
799	703	N Soda St	Jefferson	75657	House	32.7627829	-94.3476125	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
801	605	N Soda St	Jefferson	75657	New House	32.7624704	-94.3472528	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
802	606	N Soda St	Jefferson	75657	House	32.7625418	-94.3471107	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
803	607	N Soda St	Jefferson	75657	Vacant lot	32.7623555	-94.3471346	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
226	412	N Soda st	Jefferson	75657		32.7609618	-94.3455412	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
231	401	N Soda st	Jefferson	75657		32.7604527	-94.3451175	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
232	401	N Soda st	Jefferson	75657		32.7604477	-94.3451706	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know							Tier 5	
221	508	N Soda st	Jefferson	75657		32.7616979	-94.3462771	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
222	510	N Soda st	Jefferson	75657		32.7617863	-94.3463559	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
224	507	N Soda st	Jefferson	75657		32.7615348	-94.3462725	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
227	412	N Soda st	Jefferson	75657		32.7609841	-94.3455268	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
228	408	N Soda st	Jefferson	75657		32.7609300	-94.3454607	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know							Tier 5	
229	407	N Soda st	Jefferson	75657		32.7607863	-94.3455																		



Location Information					System-Owned Portion							Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers				Lead Service Line Replacement		
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>7</sup>	Notes	Entire Service Line Material Classification <sup>8</sup>	Is there a Lead Connector? <sup>9</sup>	Is there Lead Solder in the Service Line? <sup>10</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSR	Date of Customer-owned LSR
	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>																					
<p><i>A Unique ID is recommended for each service line.</i></p> <p><i>Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.</i></p> <p><i>Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field.</i></p> <p><i>Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement.</i></p> <p><i>Dropdown list when the service line was installed or replaced.</i></p> <p><i>Use this field for documenting additional relevant information, including when classification changes.</i></p> <p><i>Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.</i></p> <p><i>Date, year, or estimated date range when the service line was installed or replaced.</i></p> <p><i>Can use this field for documenting additional relevant information, including when classification changes.</i></p> <p><i>Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown.</i></p> <p><i>For example, lead gooseneck or pigtail where the water main is connected to the service line.</i></p> <p><i>Select Yes, No, or Don't Know.</i></p> <p><i>For example, backflow preventer or meter containing lead.</i></p> <p><i>Note: This information may be helpful for identifying lead tap monitoring locations.</i></p>																									
526	303	N Walnut st	Jefferson	75657	The Rowell Harris house	32.7590816	-94.3453747	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
558	202	N Walnut st	Jefferson	75657		32.7583685	-94.3443790	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Black poly	Non-Lead	Don't Know	Don't Know									Tier 5
567	205	N Walnut st	Jefferson	75657		32.7582412	-94.3450167	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Unknown	Black poly	Non-Lead	Don't Know	Don't Know									Tier 5
156	115	N Walnut St	Jefferson	75657		32.7575248	-94.3441061	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
150	114	N Walnut St	Jefferson	75657		32.7577956	-94.3438321	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
151	121	N Walnut St	Jefferson	75657		32.7577951	-94.3439940	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
522	312	N Walnut St	Jefferson	75657		32.7591936	-94.3452954	Non-Lead - Plastic	Don't Know	Unknown	poly	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
138	200	N Washington St	Jefferson	75657		32.7595552	-94.3424802	Non-Lead - Plastic	Don't Know	Unknown	Poly, Great box.	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
1208	703	N Willard St	Jefferson	75657		32.7676145	-94.3575473	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
1221	602	N Willard St	Jefferson	75657		32.7667178	-94.3571390	Non-Lead - Plastic	Don't Know	Unknown	poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
1222	602	N Willard st	Jefferson	75657		32.7670031	-94.3573812	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
445	1010	North Alley	Jefferson	75657	House	32.7716655	-94.3549096	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
466	1010	North Alley	Jefferson	75657	Faith tabernacle	32.7710912	-94.3542724	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
629	1015	North St	Jefferson	75657	House	32.7709715	-94.3417582	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
630	1400	North St	Jefferson	75657	Work Site	32.7749459	-94.3402709	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
631	1402	North St	Jefferson	75657	Work Site	32.7748944	-94.3402652	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
632	1404	North St	Jefferson	75657	Business- Work lot	32.7749259	-94.3402671	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
633	1406	North St	Jefferson	75657	Business- Work lot	32.7748838	-94.3402451	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
634	1207	North St	Jefferson	75657	House	32.7734503	-94.3409919	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
635	1209	North St	Jefferson	75657	House	32.7737412	-94.3408773	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
637	1200	North St	Jefferson	75657	Mt. Ira Baptist Church	32.7728286	-94.3410608	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
436	1113	North Walcott	Jefferson	75657	WIC	32.7718904	-94.3556809	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
437	1113	North Walcott	Jefferson	75657	Indigent Health Care	32.7718891	-94.3556816	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
438	1107	North Walcott	Jefferson	75657	Happy Hippopotamus Day Care	32.7713365	-94.3554189	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
440	1118	North Walcott	Jefferson	75657	House	32.7734600	-94.3559891	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
441	1114	North Walcott	Jefferson	75657	House	32.7725112	-94.3556145	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
444	1106	North Walcott	Jefferson	75657	House	32.7718950	-94.3551291	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
568	1006	Oak Ridge	Jefferson	75657	House	32.7707794	-94.3521022	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
463	1107	Oak Ridge Dr	Jefferson	75657	House	32.7719667	-94.3518447	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Unknown	Galvanized	Don't Know	Don't Know									Tier 5
570	1007	Oak Ridge Dr	Jefferson	75657	House	32.7708792	-94.3522607	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
571	1008	Oak Ridge Dr	Jefferson	75657	House	32.7710200	-94.3521145	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	Galvanized	Don't Know	Don't Know									Tier 5
559	1108	Oak Ridge Dr	Jefferson	75657	House	32.7720369	-94.3517170	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	With back-flow preventer	Don't Know	Don't Know									Tier 5
572	1009	Oak Ridge Dr	Jefferson	75657	House	32.7709916	-94.3522687	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	PVC	Don't Know	Don't Know									Tier 5
573	1010	Oak Ridge Dr	Jefferson	75657	House	32.7711807	-94.3521137	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	PVC	Don't Know	Don't Know									Tier 5
574	1014	Oak Ridge Dr	Jefferson	75657	House Sprinkler	32.7711777	-94.3520862	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	PVC	Don't Know	Don't Know									Tier 5
1335	274	Old Colony Rd	Jefferson	75657	Queen Horse Bedding	32.7683380	-94.3683880	Non-Lead - Plastic	Don't Know	Unknown	Poly	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
369	423	Pecan Ct	Jefferson	75657	House	32.7696918	-94.3602390	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
382	417	Pecan Ct	Jefferson	75657	House	32.7693979	-94.3593573	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
384	426	Pecan Ct	Jefferson	75657	House	32.7693836	-94.3599585	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
389	503	Pecan Ct	Jefferson	75657	House	32.7693747	-94.3616846	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
390	501	Pecan Ct	Jefferson	75657	House	32.7693721	-94.3620065	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter riser	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
391	700	Pecan Ct	Jefferson	75657	House	32.7693160	-94.3618974	Non-Lead - Copper	Don't Know	Unknown	Copper to PVC	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
383	424	Pecan Ct	Jefferson	75657	House	32.7693317	-94.3593015	Non-Lead - Plastic	Don't Know	Unknown	PVC	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
394	514	Pecan Ct	Jefferson	75657	House	32.7693020	-94.3623731	Non-Lead - Plastic	Don't Know	Unknown	Unknown	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
385	708	Pecan Way	Jefferson	75657	House	32.7695768	-94.3605983	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	PVC	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5
386	707	Pecan Way	Jefferson	75657	House	32.7696645	-94.3607029	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
387	704	Pecan Way	Jefferson	75657	House	32.7692714	-94.3611344	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
388	603	Pecan Way	Jefferson	75657	House	32.7693758	-94.3615043	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	PVC	Don't Know	Don't Know									Tier 5
393	502	Pecan way	Jefferson	75657	Vacant lot	32.7694123	-94.3623779	Non-Lead - Copper	Don't Know	Unknown	Unknown	Unknown	Unknown	Non-Lead - Other	Don't Know	Don't Know									Tier 5
399	508	Pecan Way	Jefferson	75657	House	32.7701992	-94.3616769	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	PVC	Don't Know	Don't Know									Tier 5
402	509	Pecan Way	Jefferson	75657	House	32.7700500	-94.3616942	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5
404	507	Pecan Way	Jefferson	75657	House																				



Location Information					System-Owned Portion							Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring TIERING					Lead Service Line Replacement			
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>7</sup>	Notes	Entire Service Line Material Classification <sup>8</sup>	Is there a Lead Connector? <sup>9</sup>	Is there Lead Solder in the Service Line? <sup>10</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of Entry or Point-of-Use Treatment Present? <sup>11</sup>	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988? <sup>12</sup>	Current LCR Sampling Site? <sup>13</sup>	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR		
	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>																							
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.						Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstair/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gossneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead			Note: This information may be helpful for identifying lead tap monitoring locations.							
77	312	S Alley St	Jefferson	75657		32.7586638	-94.3514180	Non-Lead - Plastic	Don't Know	Unknown	Meter box bad condition - Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know								Tier 5		
78	311	S Alley St	Jefferson	75657		32.7585514	-94.3515237	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box decent condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
124	502	S Alley st	Jefferson	75657		32.7573325	-94.3513432	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
125	409	S alley st	Jefferson	75657		32.7574384	-94.3518763	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
126	409	S alley st	Jefferson	75657		32.7574360	-94.3518994	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
76	304	S Alley St	Jefferson	75657		32.7587486	-94.3513938	Non-Lead - Plastic	Don't Know	Unknown	poly. decent box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
72	402	S Alley St	Jefferson	75657		32.7582842	-94.3514066	Non-Lead - Plastic	Don't Know	Unknown	Meter box good condition.	Non-Lead - Plastic	Unknown	Poly.	Non-Lead	Don't Know	Don't Know									Tier 5	
73	312	S Alley St	Jefferson	75657		32.7586673	-94.3514062	Non-Lead - Copper	Don't Know	Unknown	Meter box great condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
86	201	S Alley St	Jefferson	75657		32.7601304	-94.3515391	Non-Lead - Copper	Don't Know	Unknown	meter box bad condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
82	301	S Alley St	Jefferson	75657		32.7593137	-94.3517374	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
121	502	S Alley St	Jefferson	75657		32.7573604	-94.3510643	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know									Tier 5	
71	409	S Alley St	Jefferson	75657		32.7581070	-94.3515818	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know									Tier 5	
74	311	S Alley St	Jefferson	75657		32.7584655	-94.3516941	Non-Lead - Plastic	Don't Know	Unknown	Meter box bad condition. Poly.	Non-Lead - Plastic	Unknown	Meter Box Bad Condition. Poly	Non-Lead	Don't Know	Don't Know									Tier 5	
75	304	S Alley St	Jefferson	75657		32.7587502	-94.3514149	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	Poly. Meter Box Good Condition	Non-Lead	Don't Know	Don't Know									Tier 5	
128	509	S alley st	Jefferson	75657		32.7564311	-94.3519984	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
342	108	S bridge st	Jefferson	75657		32.7604649	-94.3493896	Non-Lead - Copper	Don't Know	Unknown		Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
344	202	S bridge st	Jefferson	75657		32.7601326	-94.3495455	Non-Lead - Plastic	Don't Know	Unknown		Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
101	201	S Bridge St	Jefferson	75657		32.7601759	-94.3502506	Non-Lead - Plastic	Don't Know	Unknown	poly. decent box	Non-Lead - Plastic	Unknown	PV	Non-Lead	Don't Know	Don't Know									Tier 5	
322	207	S Bridge St	Jefferson	75657		32.7597816	-94.3496420	Non-Lead - Plastic	Don't Know	Unknown		Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
321	203	S Bridge St	Jefferson	75657		32.7600925	-94.3496388	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
1347	706	S DA Dr	Jefferson	75657	House	32.7624069	-94.3636320	Non-Lead - Copper	Don't Know	Unknown		Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
1348	701	S DA Dr	Jefferson	75657	House	32.7623388	-94.3637607	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
205	205	S Delta st	Jefferson	75657		32.754485	-94.3531956	Non-Lead - Copper	Don't Know	Unknown	Poly. Good box	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
44	209	S Friou	Jefferson	75657		32.7596047	-94.3527113	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box bad	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
30	205	S Friou St	Jefferson	75657		32.7599559	-94.3527116	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
37	310	S Friou st	Jefferson	75657		32.7588434	-94.3525989	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
38	311	S Friou st	Jefferson	75657		32.7586263	-94.3527158	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
40	408	S Friou st	Jefferson	75657		32.7579181	-94.3525982	Non-Lead - Plastic	Don't Know	Unknown	Sprinkler system. Poly. Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
45	506	S Friou st	Jefferson	75657		32.7570203	-94.3526109	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
29	202	S Friou St	Jefferson	75657		32.7601270	-94.3525888	Non-Lead - Copper	Don't Know	Unknown	Meter box good	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
52	801	S Friou St	Jefferson	75657		32.7549343	-94.3525905	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
83	302	S Friou St	Jefferson	75657		32.7593468	-94.3523919	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
20	101	S Friou St	Jefferson	75657		32.7611473	-94.3526994	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know									Tier 5	
24	106	S Friou St	Jefferson	75657		32.7609199	-94.3525782	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know	Don't Know									Tier 5	
1044	502	S Houston st	Jefferson	75657		32.7502893	-94.3447421	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1045	502	S Houston st	Jefferson	75657		32.7502751	-94.3447265	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1230	101	S Hudges St	Jefferson	75657		32.7612943	-94.3615093	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1106	204	S Jackson st	Jefferson	75657		32.7531667	-94.3473488	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1107	202	S Jackson st	Jefferson	75657		32.7544836	-94.3472698	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1116	309	S Jackson st	Jefferson	75657		32.7526188	-94.3466418	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1117	308	S Jackson st	Jefferson	75657		32.7527114	-94.3465318	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
130	406	S Jefferson st	Jefferson	75657		32.7563102	-94.3509456	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good meter	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
135	408	S Jefferson st	Jefferson	75657		32.7563195	-94.3507320	Non-Lead - Plastic	Don't Know	Unknown	Poly. Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
132	402	S Jefferson st	Jefferson	75657		32.7562963	-94.3512063	Non-Lead - Copper	Don't Know	Unknown	Good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
133	402	S Jefferson st	Jefferson	75657		32.7562954	-94.3512039	Non-Lead - Copper	Don't Know	Unknown	Good box	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
136	411	S Jefferson st	Jefferson	75657		32.7564275	-94.3505523	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5	
1060	1201	S line st	Jefferson	75657		32.7511725	-94.3490711	Non-Lead - Plastic	Don't Know	Unknown	Poly - based on similar area material	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1066	1101	S line st	Jefferson	75657		32.7521332	-94.3490487	Non-Lead - Plastic	Don't Know	Unknown	Poly - based on similar area material	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5	
1072	1005	S line st	Jefferson	75657		32.7528998	-94.3490841	Non-Lead - Plastic	Don't Know	Unknown	Poly - based on similar area material																

Location Information					System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tying				Lead Service Line Replacement					
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>7</sup>	Notes	Entire Service Line Material Classification <sup>8</sup>	Is there a Lead Connector? <sup>9</sup>	Is there Lead Solder in the Service Line? <sup>10</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>																					
<p>A Unique ID is recommended for each service line.</p> <p>Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.</p> <p>Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field.</p> <p>Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement.</p> <p>Dropdown list when the service line was installed or replaced.</p> <p>Use this field for documenting additional relevant information, including when classification changes.</p> <p>Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.</p> <p>Date, year, or estimated date range when the service line was installed or replaced.</p> <p>Can use this field for documenting additional relevant information, including when classification changes.</p> <p>Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown.</p> <p>For example, lead gossneck or pigtail where the water main is connected to the service line.</p> <p>Select Yes, No, or Don't Know.</p> <p>For example, backflow preventer or meter containing lead.</p> <p>Note: This information may be helpful for identifying lead tap monitoring locations.</p>																									
1352	49	S Walcott st	Jefferson	75657		32.76208685	-94.3551048	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
1354	201	S Walcott st	Jefferson	75657		32.7603777	-94.3551655	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
1355	549	S Walcott st	Jefferson	75657		32.7560908	-94.3552686	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
1357	1761	S Walcott St	Jefferson	75657		32.7361294	-94.3528369	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
710	49	S Walcott St	Jefferson	75657		32.7613970	-94.3554695	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Other	Unknown	Cast iron	Non-Lead	Don't Know	Don't Know									Tier 5
712	105	S Walcott st	Jefferson	75657		32.7613927	-94.3558687	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1353	109	S Walcott st	Jefferson	75657		32.7603991	-94.3551589	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
3	450	S Walcott St	Jefferson	75657		32.7571582	-94.3538961	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
4	450	S Walcott St	Jefferson	75657		32.7571601	-94.3538967	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
5	402	S Walcott St	Jefferson	75657		32.7574769	-94.3539173	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
6	402	S Walcott St	Jefferson	75657		32.7574762	-94.3539175	Non-Lead - Plastic	Don't Know	Unknown	Black Poly	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
8	300	S Walcott St	Jefferson	75657		32.7592697	-94.3538720	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
9	104	S Walcott St	Jefferson	75657		32.7606890	-94.3548284	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1	371	S Walcott St	Jefferson	75657		32.7585142	-94.3553536	Non-Lead - Plastic	Don't Know	Unknown	Black Poly	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1298	206	S Willard St	Jefferson	75657		32.7599058	-94.3579158	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
614	803	Sedberry	Jefferson	75657	Treed House with 2 lots on each side	32.7696141	-94.3452318	Non-Lead - Copper	Don't Know	Unknown	Galvanized	Unknown		Galvanized Requiring Replacement	Don't Know	Don't Know									Tier 5
615	803	Sedberry	Jefferson	75657		32.7695295	-94.3459404	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
699	800	Sedberry St	Jefferson	75657		32.7692760	-94.3463686	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
679	1604	SH 49	Jefferson	75657	House	32.7733170	-94.3383980	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
1351	610	SH 49	Jefferson	75657	House	32.7623974	-94.3627253	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
671	1810	SH 49	Jefferson	75657	House	32.7755979	-94.3371196	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
672	19690	SH 49	Jefferson	75657	House	32.7761116	-94.3371930	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
673	1809	SH 49	Jefferson	75657	House	32.7756804	-94.3374614	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
674	1701	SH 49	Jefferson	75657	House	32.7745865	-94.3380375	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1710	SH 49	Jefferson	75657	House	32.7749569	-94.3374382	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know	Don't Know									Tier 5
680	1602	SH 49	Jefferson	75657	RV Park	32.7761308	-94.3385530	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
681	1600	SH 49	Jefferson	75657	Old Storefront	32.7723895	-94.3391489	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1284	201	SH 49	Jefferson	75657	House	32.7615789	-94.3563925	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1285	209	SH 49	Jefferson	75657	House	32.7616134	-94.3569453	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1286	209	SH 49	Jefferson	75657	House	32.7615773	-94.3570396	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1287	202	SH 49	Jefferson	75657	House	32.7614048	-94.3563659	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1288	204	SH 49	Jefferson	75657	House	32.7614152	-94.3564883	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1289	206	SH 49	Jefferson	75657	House	32.7614048	-94.3566684	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1290	208	SH 49	Jefferson	75657	House	32.7614004	-94.3568104	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1291	208	SH 49	Jefferson	75657	House	32.7613988	-94.3568245	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1292	210	SH 49	Jefferson	75657	House	32.7614327	-94.3571014	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1293	214	SH 49	Jefferson	75657	House	32.7613965	-94.3574678	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1336	22451	SH 49	Jefferson	75657	House	32.7638360	-94.3671690	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Copper	Unknown	May be on other water supply	Non-Lead	Don't Know	Don't Know									Tier 5
1337	22382	SH 49	Jefferson	75657	Blackburn Syrup Co	32.7647163	-94.3673232	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1338	22382	SH 49	Jefferson	75657	Blackburn Syrup - office meter	32.7647232	-94.3673280	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1339	22382	SH 49	Jefferson	75657	Blackburn Syrup - Fire Suppression meters	32.7649292	-94.3673297	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1340	22382	SH 49	Jefferson	75657	Blackburn Syrup - Fire Suppression meters	32.7649545	-94.3673216	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1341	705	SH 49	Jefferson	75657	House	32.7626732	-94.3624953	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1342	707	SH 49	Jefferson	75657	House	32.7626354	-94.3624726	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1343	709	SH 49	Jefferson	75657	House	32.7627168	-94.3626873	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1344	713	SH 49	Jefferson	75657	House	32.7628116	-94.3630921	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1345	715	SH 49	Jefferson	75657	Vacant lot	32.7629020	-94.3632491	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
1346	717	SH 49	Jefferson	75657	Funeral home	32.7629678	-94.3634620	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
682	1599	SH 49	Jefferson	75657	Shop	32.7716698	-94.3395486	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
928	601	SH 49	Jefferson	75657	House	32.7624924	-94.3609490	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Copper	Unknown		Non-Lead	Don't Know	Don't Know									Tier 5
740	406	Speake st	Jefferson	75657	House	32.7522202	-94.3513063	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know	Don't Know									Tier 5
736	406	Speake st	Jefferson																						



Location Information					System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement							
Unique Service Line ID	Location Identifier <sup>2</sup>				Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>4</sup>	Service Line Installation Date <sup>5</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>7</sup>	Notes	Entire Service Line Material Classification <sup>8</sup>	Is there a Lead Connector? <sup>9</sup>	Is there Lead Solder in the Service Line? <sup>10</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR			
	Street Number <sup>1</sup>	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>																								
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.						Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes	Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown	For example, lead gossneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead				Note: This information may be helpful for identifying lead tap monitoring locations.							
270	310	W Austin St	Jefferson	75657		32.7548325	-94.3467625	Non-Lead - Plastic	Don't Know	Unknown	poly, good box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know									Tier 5			
271	307	W Austin St	Jefferson	75657		32.7548435	-94.3469674	Non-Lead - Plastic	Don't Know	Unknown	poly, bad box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
272	307	W Austin St	Jefferson	75657		32.7548375	-94.3469819	Non-Lead - Plastic	Don't Know	Unknown	poly, bad box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
273	310	W Austin St	Jefferson	75657		32.7547556	-94.3469119	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
209	121	W Austin st	Jefferson	75657		32.7562886	-94.3449916	Non-Lead - Plastic	Don't Know	Unknown	Bad box	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know										Tier 5		
243	216	W Austin st	Jefferson	75657		32.7553875	-94.3453360	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
269	308	W Austin St	Jefferson	75657		32.7549339	-94.3466931	Non-Lead - Plastic	Don't Know	Unknown	poly, good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
279	301	W Austin St	Jefferson	75657		32.7553226	-94.3463515	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
246	201	W Austin st	Jefferson	75657		32.7560064	-94.3454490	Non-Lead - Plastic	Don't Know	Unknown	Good box	Non-Lead - Copper	Unknown	Unknown	Non-Lead	Don't Know										Tier 5		
232	134	W Bateman alley	Jefferson	75657		32.7564528	-94.3454979	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
174	119	W Bateman alley	Jefferson	75657		32.7560386	-94.3452304	Non-Lead - Plastic	Don't Know	Unknown	Non-Lead - Copper	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
182	119	W Bateman alley	Jefferson	75657		32.7566834	-94.3453201	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
169	101299	W Bateman st	Jefferson	75657		32.7569200	-94.3449252	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
173	101299	W Bateman st	Jefferson	75657		32.7568635	-94.3448711	Non-Lead - Plastic	Don't Know	Unknown	Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
183	119	W Bateman st	Jefferson	75657		32.7566852	-94.3453275	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
184	119	W Bateman st	Jefferson	75657		32.7566870	-94.3453252	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
185	119	W Bateman st	Jefferson	75657		32.7566884	-94.3453236	Non-Lead - Plastic	Don't Know	Unknown	Poly, Good box	Non-Lead - Plastic	Unknown	Poly	Non-Lead	Don't Know										Tier 5		
1229	509	W Broadway	Jefferson	75657		32.7612918	-94.3613981	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1232	501	W Broadway St	Jefferson	75657		32.7612904	-94.3605915	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1233	501	W Broadway St	Jefferson	75657		32.7612997	-94.3605927	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1308	611	W Broadway st	Jefferson	75657		32.7613856	-94.3627280	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
426	610	W Broadway st	Jefferson	75657		32.7610518	-94.3485142	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1231	507	W Broadway St	Jefferson	75657		32.7612930	-94.3609621	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1234	406	W Broadway St	Jefferson	75657		32.7615899	-94.3601601	Non-Lead - Plastic	Don't Know	Unknown	poly, 3 meters within 1 box here.	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1235	402	W Broadway St	Jefferson	75657		32.7613908	-94.3597778	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1242	407	W Broadway St	Jefferson	75657		32.7616777	-94.3595171	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1243	403	W Broadway St	Jefferson	75657		32.7616698	-94.3590891	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1244	401	W Broadway St	Jefferson	75657		32.7616430	-94.3599157	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1294	216	W Broadway st	Jefferson	75657		32.7613169	-94.3579531	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1295	304	W Broadway st	Jefferson	75657		32.7606859	-94.3580859	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1296	304	W Broadway st	Jefferson	75657		32.7604632	-94.3580770	Non-Lead - Plastic	Don't Know	Unknown	PVC	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1307	604	W Broadway st	Jefferson	75657		32.7614822	-94.3621797	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1118	409	W camp st	Jefferson	75657		32.7526418	-94.3466497	Non-Lead - Plastic	Don't Know	Unknown	Poly - based on similar area material	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know											Tier 5	
1122	512	W camp st	Jefferson	75657		32.7518737	-94.3470410	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1123	512	W camp st	Jefferson	75657		32.7518696	-94.3470509	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
489	109	W Clarksville st	Jefferson	75657		32.7594665	-94.3481165	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
490	107	W Clarksville st	Jefferson	75657		32.7595987	-94.3479919	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Unknown	Grey poly	Non-Lead	Don't Know										Tier 5		
1328	302	W Clay	Jefferson	75657	RV on vacant lot	32.7634555	-94.3575155	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1329	301	W Clay	Jefferson	75657	Single wide house - A	32.7635737	-94.3576111	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1330	301	W Clay	Jefferson	75657	Single Wide - B	32.7635676	-94.3576022	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1332	305	W Clay	Jefferson	75657	House	32.7635723	-94.3578180	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1333	306	W Clay	Jefferson	75657	House	32.7634453	-94.3577642	Non-Lead - Copper	Don't Know	Unknown	Non-Lead - Plastic	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1003	101	W Clay	Jefferson	75657	Shop	32.7635617	-94.3556895	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1022	202	W Clay	Jefferson	75657	House	32.7634592	-94.3564738	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1025	210	W Clay	Jefferson	75657	Double wide	32.7634668	-94.3569085	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1026	205	W Clay	Jefferson	75657	Single wide house	32.7635889	-94.3569613	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1028	207	W Clay	Jefferson	75657	Single wide house	32.7635982	-94.3569505	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1029	203	W Clay	Jefferson	75657	Single wide house	32.7636025	-94.3569597	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1030	209	W Clay	Jefferson	75657	Single wide house	32.7635853	-94.3570325	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Copper	Unknown	PVC	Non-Lead	Don't Know										Tier 5		
1331	301																											



Location Information						System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers				Lead Service Line Replacement			
Unique Service Line ID	Location Identifier <sup>2</sup>					System-Owned Portion Service Line Material Classification <sup>1</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>4</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>5</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSR	Date of Customer-owned LSR	
	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>	Other Location Identifier <sup>1</sup>																			GPS Coordinate - Latitude (decimal degrees)
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.					Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes	Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown	For example, lead gossneck or pithead where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead			Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSR	Date of Customer-owned LSR	
1096	302	W lake st	Jefferson	75657		32.7542798	-94.3455308	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1097	304	W lake st	Jefferson	75657		32.7541551	-94.3458595	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1098	302	W lake st	Jefferson	75657		32.7540289	-94.3459705	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1108	503	W lake st	Jefferson	75657		32.7531656	-94.3473396	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1109	503	W lake st	Jefferson	75657		32.7531746	-94.3473293	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1111	507	W lake st	Jefferson	75657		32.7529079	-94.3477859	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1113	502	W lake st	Jefferson	75657		32.7529529	-94.3474243	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1114	508	W lake st	Jefferson	75657		32.7525767	-94.3478836	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1115	508	W lake st	Jefferson	75657		32.7525936	-94.3479286	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
481	105	W Orleans st	Jefferson	75657		32.7589441	-94.3471986	Non-Lead - Plastic	Don't Know	Unknown	Black poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1109	109	W Seaberry	Jefferson	75657	House	32.7655842	-94.3557357	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1157	110	W Seaberry	Jefferson	75657	House	32.7693545	-94.3557845	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1158	107	W Seaberry	Jefferson	75657	House	32.7694982	-94.3555209	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
1159	104	W Seaberry	Jefferson	75657	Tax service	32.7693611	-94.3554492	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
1160	107	W Seaberry	Jefferson	75657	Shop	32.7697016	-94.3550655	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1312	105	W Sharp	Jefferson	75657	House	32.7656957	-94.3557216	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1220	211	W Sharp St	Jefferson	75657		32.7664919	-94.3570620	Non-Lead - Plastic	Don't Know	Unknown	blue poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
906	703	w watson	Jefferson	75657		32.7645829	-94.3627729	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1320	203	W Watson	Jefferson	75657	House	32.7645758	-94.3567083	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1321	201	W Watson	Jefferson	75657	House	32.7645842	-94.3571357	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1323	208	W Watson	Jefferson	75657	Vacant lot	32.7644602	-94.3570372	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
1324	302	W Watson	Jefferson	75657	Abandoned house	32.7644142	-94.3574545	Non-Lead - Copper	Don't Know	Unknown	No meter found	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1325	304	W Watson	Jefferson	75657	House	32.7644401	-94.3577253	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1016	202	W Watson	Jefferson	75657	Duplex	32.7644597	-94.3562497	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1032	206	W Watson	Jefferson	75657	Single wide house	32.7643191	-94.3565907	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1033	204	W Watson	Jefferson	75657	Single wide house	32.7643431	-94.3565754	Non-Lead - Plastic	Don't Know	Unknown	Poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1257	601	W Watson St	Jefferson	75657		32.7645261	-94.3601799	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
1258	503	W Watson St	Jefferson	75657		32.7646058	-94.3597249	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
1259	501	W Watson St	Jefferson	75657		32.7645305	-94.3595655	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
1260	502	W Watson St	Jefferson	75657		32.7644049	-94.3594681	Non-Lead - Plastic	Don't Know	Unknown	poly	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
111	111	W Whelan	Jefferson	75657	House	32.7702389	-94.3538896	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
431	110	W Whelan	Jefferson	75657	Vacant House	32.7701443	-94.3559704	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
433	104	W Whelan	Jefferson	75657	House	32.7701569	-94.3554591	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
434	102	W Whelan	Jefferson	75657	Old Storefront	32.7700165	-94.3551061	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Galvanized	Non-Lead - Plastic	Don't Know	Galvanized Requiring Replacement									Tier 5
141	113	Washington St	Jefferson	75657		32.7591504	-94.3422984	Non-Lead - Plastic	Don't Know	Unknown	poly, decent box	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
140	115	Washington St	Jefferson	75657		32.7589638	-94.3423291	Non-Lead - Plastic	Don't Know	Unknown	Poly. Meter box good condition.	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
466	1008	westview	Jefferson	75657		32.7709697	-94.3531118	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
467	1007	westview	Jefferson	75657		32.7709267	-94.3533283	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
468	1006	westview	Jefferson	75657		32.7707683	-94.3531683	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
469	1011	westview	Jefferson	75657		32.7711800	-94.3532633	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
451	1107	Westview Dr	Jefferson	75657	House	32.7715595	-94.3531589	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
453	104	Westview Dr	Jefferson	75657	House	32.7717125	-94.3529510	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
465	1011	Westview dr	Jefferson	75657		32.7710884	-94.3533356	Non-Lead - Copper	Don't Know	Unknown	Unknown	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
527	511	Woodland	Jefferson	75657	House	32.7710694	-94.3492226	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
528	509	Woodland	Jefferson	75657	House	32.7713742	-94.3497251	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
530	504	Woodland	Jefferson	75657	House	32.7713784	-94.3501755	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to Meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
532	506	Woodland	Jefferson	75657	House	32.7712821	-94.3499276	Non-Lead - Copper	Don't Know	Unknown	Copper to Poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
533	508	Woodland	Jefferson	75657	House	32.7710302	-94.3494301	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
535	512	Woodland	Jefferson	75657	Shop house	32.7708256	-94.3490868	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
537	514	Woodland	Jefferson	75657	House	32.7709609	-94.3492522	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
538	516	Woodland	Jefferson	75657	House	32.7708805	-94.3486547	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
557	401	Woodland	Jefferson	75657	House	32.7714961	-94.3514177	Non-Lead - Copper	Don't Know	Unknown	Riser	Non-Lead - Copper	Don't Know	Don't Know									Tier 5	
452	307	Woodland Dr	Jefferson	75657	House	32.7715732	-94.3524634	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Non-Lead - Plastic	Don't Know	Don't Know									Tier 5	
552	408	Woodland Dr	Jefferson	75657	House	32.7711864	-94.3509666	Non-Lead - Copper	Don't Know	Unknown	Copper to poly to meter	Galvanized	Non-Lead - Plastic	Don't Know	Galvanized Requiring Replacement								Tier 5	

Location Information						System-Owned Portion				Customer-Owned Portion				Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiers					Lead Service Line Replacement		
Unique Service Line ID	Location Identifier <sup>2</sup>					System-Owned Portion Service Line Material Classification <sup>3</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes	Entire Service Line Material Classification <sup>3</sup>	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>2</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR	
	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>	Other Location Identifier <sup>1</sup>																			GPS Coordinate - Latitude (decimal degrees)
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.					Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes four required service line classifications of Lead, Non-Lead, Galvanized Requiring Replacement, or Unknown	For example, lead gossneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead								
1239	406	W Broadway St	Jefferson	75657		32.7617035	-94.3506313	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1240	406	W Broadway St	Jefferson	75657		32.7616910	-94.3506885	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1300	304	W Broadway St	Jefferson	75657		32.7609884	-94.3582236	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1058	712	W Camp St	Jefferson	75657		32.7505694	-94.3489055	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1374	202	W Dallas	Jefferson	75657		32.7554600	-94.3452389	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1376	208	W Dallas	Jefferson	75657		32.7545990	-94.3451239	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1201	413	W Douglas St	Jefferson	75657		32.7675854	-94.3603812	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1202	411	W Douglas St	Jefferson	75657		32.7675803	-94.3600070	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1203	406	W Douglas St	Jefferson	75657		32.7674276	-94.3592345	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1204	407	W Douglas St	Jefferson	75657		32.7675902	-94.3595945	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1205	407	W Douglas St	Jefferson	75657		32.7678657	-94.3595738	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1223	212	W Douglas St	Jefferson	75657		32.7674054	-94.3572484	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1224	304	W Douglas St	Jefferson	75657		32.7674072	-94.3573452	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1175	402	W Harrison St	Jefferson	75657		32.7684323	-94.3587562	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1176	402	W Harrison St	Jefferson	75657		32.7684171	-94.3587341	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1177	403	W Harrison St	Jefferson	75657		32.7685345	-94.3587103	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1189	502	W Harrison St	Jefferson	75657		32.7683440	-94.3606634	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1190	504	W Harrison St	Jefferson	75657		32.7683644	-94.3609499	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1191	409	W Harrison St	Jefferson	75657		32.7685829	-94.3592656	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1280	120	W Lafayette St	Jefferson	75657		32.7570942	-94.3455389	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1104	406	W Lake St	Jefferson	75657		32.7538864	-94.3463406	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1110	408	W Lake St	Jefferson	75657		32.7531230	-94.3469013	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
907	808	W Watson St	Jefferson	75657		32.7643848	-94.3628304	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can't Locate	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1269	402	W Watson St	Jefferson	75657		32.7643914	-94.3586777	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1270	402	W Watson St	Jefferson	75657		32.7641893	-94.3586791	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
435	111	W Whelan St	Jefferson	75657	JISD Transportation department	32.7706678	-94.3552165	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Unable	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
1381	111	W Whelan St	Jefferson	75657		32.7703052	-94.3555956	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
972	303	E Clay	Jefferson	75657	House	32.7635867	-94.3520415	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
975	305	E Clay	Jefferson	75657	House	32.7634230	-94.3509868	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
976	404	E Clay	Jefferson	75657	House	32.7635550	-94.3507370	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
975	404	E Clay	Jefferson	75657	House	32.7635802	-94.3511677	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
958	109	E Clay	Jefferson	75657	House	32.7635528	-94.3541263	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
819	604	E Clay St	Jefferson	75657	Single wide house	32.7634199	-94.3490310	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	No meter found- possible double connection with 602	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
895	209	E Douglas	Jefferson	75657	Vacant lot	32.7676103	-94.3529445	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
894	212	E Douglas	Jefferson	75657	House	32.7674270	-94.3529317	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
901	610	E Douglas	Jefferson	75657	House - May be connected to 312 N Alley	32.7674049	-94.3517038	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
942	210	E Elizabeth	Jefferson	75657	House and shop	32.7624701	-94.3533831	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
948	210	E Elizabeth	Jefferson	75657	Shop	32.7623202	-94.3537283	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
805	0	E Elizabeth St	Jefferson	75657	Vacant lot	32.7626998	-94.3503233	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
808	502	E Watson	Jefferson	75657	Treed lot	32.7635828	-94.3501744	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
873	301	E Webster	Jefferson	75657	Abandoned house	32.7665408	-94.3523210	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
874	215	E Webster	Jefferson	75657	Abandoned house- lot	32.7665822	-94.3527497	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
450	1007	E Whelan	Jefferson	75657	House	32.7707160	-94.3541118	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
445	103	E Whelan	Jefferson	75657	House	32.7708252	-94.3541953	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
606	812	Loverne	Jefferson	75657	Vacant house	32.7730556	-94.3447056	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
619	0	Line St	Jefferson	75657	Cedar Grove Cemetery	32.7723207	-94.3483862	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
627	901	Mulberry	Jefferson	75657	Farm Lot	32.7705520	-94.3440370	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
825	804	N Alley	Jefferson	75657	Jefferson middle school	32.7686865	-94.3513999	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
865	706	N Alley	Jefferson	75657	House	32.7678963	-94.3516435	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
815	200	N Bridge St	Jefferson	75657	Vacant lot	32.7626663	-94.3494814	Unknown - Material Unknown	Don't Know	Unknown	Unable to locate	Unknown - Material Unknown	Unknown	Unknown	Can	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Tier 5	
834	700	N Line St	Jefferson	75657</																				



Unique Service Line ID	Location Information				System-Owned Portion				Customer-Owned Portion			Entire Service Line Material Classification <sup>6</sup>	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement				
	Street Number <sup>4</sup>	Street Name <sup>4</sup>	City <sup>4</sup>	Zip Code <sup>4</sup>	Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>5</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>3</sup>	Service Line Installation Date <sup>1</sup>	Notes		Customer-Owned Portion Service Line Material Classification <sup>6</sup>	Service Line Installation Date <sup>1</sup>	Notes	Is there a Lead Connector? <sup>2</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS Coordinate - Latitude/Longitude fields and include 5 decimal places.				Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field				Select Yes, No, or Don't know. Important for determining if downstream/customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know	For example, backflow preventer or meter containing lead	Note: This information may be helpful for identifying lead tap monitoring locations.						
199	211	N Polk st	Jefferson	75657		32.7577722	-94.3456642	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
200	219	N Polk st	Jefferson	75657		32.7580752	-94.3461438	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
325	607	N Polk St	Jefferson	75657		32.7606825	-94.3489943	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Under Asphalt Road, can't dig	Unknown	Don't Know	Don't Know							Tier 5	
326	607	N Polk St	Jefferson	75657		32.7606466	-94.3490085	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Under Asphalt Road	Unknown	Don't Know	Don't Know							Tier 5	
347	607	N Polk st	Jefferson	75657		32.7610876	-94.3487534	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Filled With Water	Unknown	Don't Know	Don't Know							Tier 5	
491	505	N Polk st	Jefferson	75657		32.7601161	-94.3477199	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Under sidewalk. Can't tell	Unknown	Don't Know	Don't Know							Tier 5	
500	402	N Polk St	Jefferson	75657		32.7592896	-94.3464672	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	missing meter	Unknown	Don't Know	Don't Know							Tier 5	
501	318	N Polk St	Jefferson	75657		32.7592171	-94.3463814	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	meter missing	Unknown	Don't Know	Don't Know							Tier 5	
193	212	N Vale st	Jefferson	75657		32.7578080	-94.3461279	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
706	102	N Walcott st	Jefferson	75657		32.7620023	-94.3548390	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Meter too deep. Not likely lead based off location and neighboring box materials	Unknown	Don't Know	Don't Know							Tier 5	
152	123	N Walnut St	Jefferson	75657		32.7579068	-94.3440225	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Capped line.	Unknown	Don't Know	Don't Know							Tier 5	
153	126	N Walnut St	Jefferson	75657		32.7579125	-94.3440108	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Capped line	Unknown	Don't Know	Don't Know							Tier 5	
154	115	N Walnut St	Jefferson	75657		32.7576545	-94.3438427	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	2 Capped Lines	Unknown	Don't Know	Don't Know							Tier 5	
155	120	N Walnut St	Jefferson	75657		32.7580704	-94.3441184	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Sealed in concrete	Unknown	Don't Know	Don't Know							Tier 5	
515	420	N Walnut St	Jefferson	75657		32.7602000	-94.3463247	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	missing meter	Unknown	Don't Know	Don't Know							Tier 5	
88	302	S Alley St	Jefferson	75657		32.7593681	-94.3513159	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	poly. decent condition box	Unknown	Don't Know	Don't Know							Tier 5	
21	101	S Friou St	Jefferson	75657		32.7611417	-94.3527020	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Abandoned cut off city line. Meter box good condition	Unknown	Don't Know	Don't Know							Tier 5	
25	112	S Friou St	Jefferson	75657		32.7606365	-94.3525727	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	2 Meters. Meter Box Good Condition	Unknown	Don't Know	Don't Know							Tier 5	
35	306	S Friou st	Jefferson	75657		32.7589872	-94.3525815	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Too Deep	Unknown	Don't Know	Don't Know							Tier 5	
41	408	S Friou st	Jefferson	75657		32.7576511	-94.3525994	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Filled With Water	Unknown	Don't Know	Don't Know							Tier 5	
137	411	S Jefferson st	Jefferson	75657		32.7564229	-94.3505403	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Filled With Water	Unknown	Don't Know	Don't Know							Tier 5	
244	202	S Market st	Jefferson	75657		32.7548607	-94.3453794	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	All 4 meters come from 1 city line, material unknown. 2 meters are disconnected. Good box	Unknown	Don't Know	Don't Know							Tier 5	
266	101	S Market St	Jefferson	75657		32.7552623	-94.3462093	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
265	204	S Marshall St	Jefferson	75657		32.7548072	-94.3458647	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
262	102	S Polk St	Jefferson	75657		32.7566587	-94.3436363	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
263	102	S Polk St	Jefferson	75657		32.7567725	-94.3440911	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
655	1458	S Polk St	Jefferson	75657		32.7452121	-94.3391020	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
713	105	S Walcott st	Jefferson	75657		32.7613702	-94.3557967	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Can't find box. Non lead based on closest box materials	Unknown	Don't Know	Don't Know							Tier 5	
10	200	S Walcott st	Jefferson	75657		32.7602902	-94.3544119	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Unknown. Bad meter box.	Unknown	Don't Know	Don't Know							Tier 5	
282	602	Taylor St	Jefferson	75657		32.7548555	-94.3490117	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	good box	Unknown	Don't Know	Don't Know							Tier 5	
204	124	W Austin st	Jefferson	75657		32.7558261	-94.3464715	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
206	124	W Austin st	Jefferson	75657		32.7560966	-94.3450530	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Filled With Dirt. No Meter Detected. Good Box	Unknown	Don't Know	Don't Know							Tier 5	
208	113	W Austin st	Jefferson	75657		32.7563839	-94.3449199	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Bad box	Unknown	Don't Know	Don't Know							Tier 5	
210	121	W Austin st	Jefferson	75657		32.7562144	-94.3451152	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
249	211	W Austin st	Jefferson	75657		32.7562238	-94.3458773	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Pvc	Unknown	Don't Know	Don't Know							Tier 5	
267	306	W Austin St	Jefferson	75657		32.7550407	-94.3464608	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
168	101299	W Bateman alley	Jefferson	75657		32.7570326	-94.3448284	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
1192	411	W Harrison St	Jefferson	75657		32.7685462	-94.3595807	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown		Unknown	Don't Know	Don't Know							Tier 5	
177	1920	W Lafayette st	Jefferson	75657		32.7571665	-94.3452296	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
189	119	W Lafayette st	Jefferson	75657		32.7571731	-94.3461760	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
254	209	W Lafayette st	Jefferson	75657		32.7570021	-94.3462004	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
255	209	W Lafayette st	Jefferson	75657		32.7569954	-94.3461933	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	Good box	Unknown	Don't Know	Don't Know							Tier 5	
276	408	W Lafayette St	Jefferson	75657		32.7549439	-94.3480948	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	bad box	Unknown	Don't Know	Don't Know							Tier 5	
277	402	W Lafayette St	Jefferson	75657		32.7549495	-94.3480900	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	bad box	Unknown	Don't Know	Don't Know							Tier 5	
278	304	W Lafayette St	Jefferson	75657		32.7558922	-94.3473200	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	capped decent box	Unknown	Don't Know	Don't Know							Tier 5	
1326	306	W Watson	Jefferson	75657	Vacant lot	32.7644390	-94.3578015	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	No meter shown on map	Unknown	Don't Know	Don't Know							Tier 5	
428	201	W Whelan	Jefferson	75657	Bus Barn	32.7700957	-94.3565722	Unknown - Material Unknown	Don't Know	Unknown	Need to re-inspect	Unknown - Material Unknown	Unknown	City unable to locate meter	Unknown	Don't Know	Don't Know							Tier 5	



# Public Accessibility Documentation

PWS Name: City of Jefferson

PWSID: TX1580001

**Purpose of this worksheet:** For systems to provide documentation to states on how public accessibility requirements of the LCRR were met. *All information on this page is required.*

*Remember that the LCRR requires systems to use a location identifier for service lines that are lead and galvanized requiring replacement. Water systems may, but are not required to, include a locational identifier for lead status unknown service lines or list the exact address of each service line (40 CFR §141.84(a)(8)(i)).*

1. Select the location identifiers that you use for your service line inventory. Check all that apply.\*

Address	Yes	GPS Coordinates	Yes
Street	Yes	Other	Yes

*If "Other" is Yes, please describe below:*

Some locations have descriptors of type of structure or lot

2. Does **every service line** have a location identifier? *If "No", explain below.* \*

Yes

3. How is the inventory made publicly accessible? Check all that apply. *Remember that if your system serves > 50,000 people, you **must** provide the inventory online.* \*

Interactive online map	No	Printed tabular data	No
Static online map	No	Information on water utility mailings or newsletter	No
Online spreadsheet	No	Hard copy information available in water system office	Yes
Printed service line map	No	Other	No

*If "Other" is Yes, please describe below:*

## PWS Certification

PWS Name: City of Jefferson

PWSID: TX1580001

**Certify completion of your lead service line inventory by checking the appropriate boxes below, entering your water system information, and signing the certification. All information on this page is required.**

<i>I certify</i>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.
<i>I certify</i>	As the PWS Representative, I understand that if any additional service lines are subsequently identified as Lead, Galvanized Requiring Replacement, or Lead Status Unknown, the PWS is required to notify the State within 30 days of identifying the service line(s) and must prepare an updated inventory using Lead Service Line Inventory.
<i>I certify</i>	As the PWS Representative, I understand that the PWS should maintain for review any resource, information, or identification method used for the development of this initial inventory. These records do not need to be submitted to TCEQ but should be available for review.
<i>I certify</i>	As the PWS representative, I understand that customers with a lead, galvanized requiring replacement, or lead status unknown service lines should be informed within 30 days of completion of initial LSLI and annually thereafter until the service line is replaced.
<i>I certify</i>	As the PWS representative, I understand that the PWS should provide an updated LSLI in accordance with its tap sampling monitoring period schedule, but no more frequently than annually. The updated LSLI must be submitted within 30 days of the end of each tap sampling period.
<i>Lisa Crossman, P.E.</i>	The individual providing certification and acknowledgment to the above statements.